



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1845954

Master Contract: 208866

Project: 1845954

Date Issued: 2006/11/07

Issued to: GP:50 New York Ltd.
2770 Long Rd
Grand Island, NY 14072
USA
Attention: Amy Napieralski

The products listed below are eligible to bear the CSA Mark shown



Issued by: Rob Kohuch E.I.T.

Authorized by: Patricia Pasemko, Operations
Manager

PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Part A

Class I, Division 1, Groups A, B, C, D, Class II, Groups E,F,G, Class III.

Maximum Ambient 80° C, Temp Code T5. Enclosure Type 4.

1171 Series Pressure Transmitter, Input: 36 Vdc max, 250mA max

Part B



Certificate: 1845954

Master Contract: 208866

Project: 1845954

Date Issued: 2006/11/07

Class I, Division 1, Groups A, B, C, D, Class II, Groups E,F,G, Class III.

Maximum Ambient 40° C, Temp Code T6. Enclosure Type 4.

MDL Series Pressure Transducer, Input: 40 Vdc max, 250mA max

Models 210, 310, 111, 211, 311, 411, 114, 214, 314, 414, 115, 215, 315, 415, 117, 217, 317, 417, 216, 316, 130, 230, 330, 430, 131, 231, 331, 431, 280, 380

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No 0 M91 General Requirements Canadian Electrical Code Part II.

CSA Standard C22.2 No 0.4 04 Bonding of Electrical Equipment.

CSA Standard C22.2 No 25-1966 Enclosures for use in Class II, Groups E, F, and G.

CSA Standard C22.2 -30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CSA Standard C22.2 No 94-M91 Special Purpose Enclosures.

CSA Standard C22.2 -142-M1987 - Process Control Equipment